

Zeta Battery Operated Detectors

(ZT-ST5, ZT-ST5/10 & ZT-TH5)



Description

The ZT-ST5 & ZT-ST5/10 stand-alone photoelectric residential smoke alarms are NF approved and can be calibrated to either UL, BSI or VdS requirements.

They feature VdS and UL-approved photoelectric sensing components with precise smoke detection and long life operation (1 year life with a 9V common alkaline battery) or (10 years with 9V Li battery). A proved quality with 10 million pieces installed over the world. Russian standard model available too.

The ZT-TH5 stand-alone heat detector was designed with precise microprocessor control integrating both Rate-of-Rise and Fixed Temperature heat detection.

It's perfectly suitable for installation in all environments especially the kitchen, garage, factory etc. The ZT-TH5 meets EN 54-5 standards.



Technical Specification

Model	ZT-ST5	ZT-ST5/10	ZT-TH5
Part Number	47-037	47-037-10	47-035
Smoke Sensitivity	(2.31 ± 1.37)% / ft Obscuration (UL standard) 0.010 dB/m to 0.160 dB/m (VdS EN 14604)		
Power supply	9V battery	9V lithium battery	9V battery
Battery life	1 Year	10 Years	1 Year
Low battery life	Up to 30 days warning signal		
Alarm indicator	Continuously emitting red light		Red LED Flashing
Alarm sound level	85dB at 3m		Exceeding 85dB at 3m
Operating Temp.	0°C to 50°C		
Humidity	10% to 95%RH, no condensation or icing		
Interconnection	Up to 38 units		

Features

- ✔ Photoelectric sensing technology (ZT-ST5 & ZT-ST5/10)
- ✔ Electronic thermistor sensing technology (ZT-TH5)
- ✔ Easy installation and maintenance.
- ✔ Sealed Battery case of the back available (with 10-year Li Battery model)
- ✔ Sleek low-profile design
- ✔ SMD circuit board design - quality and reliability guaranteed
- ✔ Low-battery warning
- ✔ Test button verifies battery and alarm operation
- ✔ Loud alarm signal of exceeding 85 dB in alarm mode
- ✔ Five-year limited warranty
- ✔ HUSH button, to stop the alarm from sounding
- ✔ 10-year Long-life lithium battery (ZT-ST5/10 only)
- ✔ The power supply will be cut out automatically when removing the detector from the base